

Town of Orangetown
BUREAU OF FIRE PREVENTION
20 Greenbush Road
Orangeburg, NY 10962
Ph (845)365-0204*fax (845)365-0241

CARBON MONOXIDE ALARM/DETECTOR GUIDELINES

BATTERY OPERATED CARBON MONOXIDE ALARM:

10 YEAR BATTERY
UL 2034 LISTING

INSTALLED PER MANUFACTURES SPECIFICATIONS

DO NOT INSTALL WITHIN 15 FEET OF A FUEL FIRED APPLIANCE

INSTALL IN ANY ROOM WITH A CARBON MONOXIDE SOURCE