

Town of Orangetown
Bureau of Fire Prevention
20 Greenbush Road
Orangeburg, New York 10962
Ph(845)365-0204*fax(845)365-0241

EMERGENCY LIGHTING TEST FORM
(lighting must be run tested for 90 continuous minutes)

| <u>FIXTURE #</u> | <u>PASS</u> | <u>FAIL (check one)</u> |
|------------------|-------------|-------------------------|
| 1) | | |
| 2) | | |
| 3) | | |
| 4) | | |
| 5) | | |
| 6) | | |
| 7) | | |
| 8) | | |
| 9) | | |
| 10) | | |

I (print name) _____ have tested the emergency lighting
fixtures at (address & name of
business) _____

On (date) ____/____/____

Signature _____